CERTIFICATE OF COMPLIANCE
SEISMIC DESIGN OF NONSTRUCTURAL COMPONENTS AND SYSTEMS

Certification No.

VMA-53972-01C (Revision 4)

Expiration Date: 3/31/2027

Certification Parameters:

The nonstructural products (mechanical and/or electrical components) listed on this certificate are CERTIFIED[1] FOR SEISMIC APPLICATIONS in accordance with the following building code[2] releases.

IBC 2024, 2021, 2018, 2015

The following model designations, options, and accessories are included in this certification. Reference report number VMA-53972-01 as issued by VMC Group for a complete list of certified models, included accessories/options, and certified installation methods.

Generac Power Systems, Inc.; Transfer Switches
TX301, TX611, & TX671; 100A - 1000A

The above referenced equipment is **APPROVED** for seismic application when properly installed[3], used as intended, and contains a Seismic Certification Label referencing this Certificate of Compliance[4]. As limited by the tabulated values, below grade, grade, and roof-level installations, installations in essential facilities, for life safety applications, and/or of equipment containing hazardous contents are permitted and included in this certification with an Equipment Importance Factor assigned as I_p=1.5. The equipment is qualified by successful seismic shake table testing at the nationally recognized Dynamic Certification Laboratories under the witness of the ISO Accredited Product Certification Agency, the VMC Group.

Certified Seismic Design Levels			
Certified **IBC**	**Importance $I_p \leq 1.5$** Soil Classes A-E Risk Categories I-IV Design Categories A-F	z/h ≤ 1.0	z/h = 0.0
		$S_{DS} \leq 2.000$ g	$S_{DS} \leq 2.500$ g

Certified Seismic Installation Methods[8]	
Directly To Structural Wall	Combination Rigid Mounting from Unit Base to Rigid Structure and Directly to Structural Wall

CERTIFICATE OF COMPLIANCE

SEISMIC DESIGN OF NONSTRUCTURAL COMPONENTS AND SYSTEMS

Certified Product Table:

Unit Type	Generac Model No.	Rating [A]	Max Length [in]	Max Depth [in]	Max Height [in]	NEMA Rating	Max Weight [lb]	Mounting Configuration
Non- Service Entrance Rated	TX611xN0100xxxx	100	21	12	36	1, 3R	155	Wall Mounted
	TX301xN0xxxxxxx	150, 200					165	
	TX611xN0xxxxxxx							
	TX301xN0300xxxx	300	24		51		185	
	TX611xN0300xxxx							
	TX611xN0400xxxx	400						
	TX301xN0400xxxx							
	TX611xN0600xxxx	600	29	15	64		225	
Service Entrance Rated	TX301xS0100xxxx	100	21	12	51	1, 3R	215	Wall Mounted
	TX301xS0150xxxx	150					225	
	TX301xS0200xxxx	200						
	TX301xS0300xxxx	300	34				273	
	TX301xS0400xxxx	400						
Non-Service Entrance Rated	TX611xN0600xxxx	600	30	25	81	1, 12	460	Combo Base and Wall Mounted
	TX611xN0800xxxx	800				1, 12, 3R	650	
	TX671xN1000xxxx	1000				1, 3R		
Service Entrance Rated	TX301xS0600xxxx	600	30	24	81	1, 3R	467	Combo Base and Wall Mounted
	TX301xS0800xxxx	800	38	25	90		880	
	TX301xS1000xxxx	1000					890	

Note: Model numbers are custom; for detailed allowable model numbers please contact manufacturer.

Type	S_{DS} (z/h=0)	S_{DS} (z/h=1)	A_{Flex-H}	A_{Rig-H}	A_{Flex-V}	A_{Rig-V}	(ASCE7-16) F_p/W_p	(ASCE7-22) F_p/W_p
AC156	2.50	2.00	3.20	2.40	1.67	0.67	1.50	2.26

This certification includes the product and factory supplied accessories and options. The product and included accessories and options shall be a catalogue design and factory supplied. The product shall be installed and attached to the building structure per the manufacturer supplied seismic installation instructions. For a list of certified configurations and options please directly contact the manufacturer. This certification excludes all non-factory supplied accessories, including but not limited to enclosures, isolation/restraint devices, remote control panels, mounting brackets, and other electrical/mechanical components.

VMA-53972-01C (Revision 4)
Issue Date: March 1, 2021
Revision Date: October 24, 2025
Expiration Date: March 31, 2027

CERTIFICATE OF COMPLIANCE
SEISMIC DESIGN OF NONSTRUCTURAL COMPONENTS AND SYSTEMS

Notes & Comments:

1. All equipment listed herein successfully passed the seismic acceptance criteria for shake testing non-structural components and systems as set forth in the ICC AC-156. The Test Response Spectrum (TRS) enveloped the Required Response Spectrum (RRS) for all units tested. The tested units were representative sample(s) of a contingent of models and all remained captive and structurally sound after the seismic shake simulation. The units also remained functionally operational after the simulation testing as functional testing was completed by the equipment manufacturer before and after the seismic simulations. Although a seismic qualified unit inherently contains some wind resisting capacity, that capacity is undetermined and is excluded from this certification. Snow/Ice loads have been neglected and thus limit the unit to be installed both indoors (covered by an independent protective structure) and out of doors (exposed to accumulating snow/ice) for ground snow loads no greater than 30 psf for all applications.

2. The following building codes are addressed under this certification:
   IBC 2024 referencing ASCE7-22 and ICC-ES AC-156
   IBC 2021 referencing ASCE7-16 and ICC-ES AC-156
   IBC 2018 referencing ASCE7-16 and ICC-ES AC-156
   IBC 2015 referencing ASCE7-10 and ICC-ES AC-156

3. Refer to the manufacturer supplied installation drawings for anchor requirements and mounting considerations for seismic applications. Required anchor locations, size, style, and load capacities (tension and shear) may be specified on the installation drawings or specified by a 3rd party. Mounting requirement details such as anchor brand, type, embedment depth, edge spacing, anchor-to-anchor spacing, concrete strength, special inspection, wall design, and attachment to non-building structures must be outlined and approved by the Engineer of Record for the project or building. Structural walls, structural floors, and housekeeping pads must also be seismically designed and approved by the project or building Structural Engineer of Record to withstand the seismic anchor loads as defined on the installation drawings. The installing contractor is responsible for ensuring the proper installation of all anchors and mounting hardware.

4. For this certificate and certification to remain valid, this certificate must correspond to the "Seismic Certification Label" found affixed to the unit by the factory. The label ensures the manufacturer built the unit in conformance to the IBC seismic design criteria set forth by the Certified Seismic Qualification Agency, the VMC Group, and meets the seismic design levels claimed by this certificate.

5. Mechanical, Electrical, and Plumbing connections to the equipment must be flexibly attached as to not transfer load through the connection. The structural integrity of any conduit, cable trays, piping, ductwork and/or flexible connections is the responsibility of others. This certification makes no statements of compliance in regards to NEMA, IP, UL, CSA, or other relevant standards after a seismic event. For compliance to other relevant standards, please contact the manufacturer.

6. This certificate applies to units manufactured at:
   S45 W29290 Hwy 59 Waukesha, WI 53189

7. This certification follows the VMC Group's ISO-17065 Scheme.

8. The certified seismic installation methods stated are a summary for all product lines this certificate covers. For individual certified seismic installation methods, see the certified product tables.

John P. Giuliano, PE
President, VMC Group

VMA-53972-01C (Revision 4)
Issue Date: March 1, 2021
Revision Date: October 24, 2025
Expiration Date: March 31, 2027